



SEE SHEET C-2 FOR PIPING DETAILS

- NOTES:
1. WELD 8" FLANGED PIPE TO 14" AIR PIPE AT EACH DISCHARGE SILENCER - SEE (1) (D-1)
  2. WELD 8" FLANGED PIPE TO 14" AIR PIPE FOR FUTURE BLOWER - SEE (1) (D-1)
  - INSTALL 8" BLIND FLANGE. LOCATION TO BE VERIFIED.
  3. WEST ENDS OF BOTH 14" AIR PIPES MUST BE SEALED BY WELDING.
  4. CUT OUT SECTION OF 14" AIR PIPE AFTER BLOWERS HAVE BEEN RELOCATED AT C OF NORTH-SOUTH LEVEE AND WELD A STEEL PLATE TO END. INSTALLATION MUST BE COATED AND COVERED IN ACCORDANCE WITH SECTION 15061. SEE AERATOR CONTROL BUILDING SITE FOR LOCATION.

PLAN VIEW

Record Drawing *Raymond P. Stehman*

REV.	DATE	DESCRIPTION	BY

  

<b>EQUIPMENT LAYOUT</b>	
<b>BLOWER AND SWITCH GEAR BUILDING MANDAN, NORTH DAKOTA</b>	
<b>ULTEIG ENGINEERS, INC.</b> CONSULTING ENGINEERS • FARGO • BISMARCK • MINNEAPOLIS	
DRAWN BY: BJH	SCALE: AS SHOWN
CHECKED BY: RR	DATE: NOV. 1988
APPROVED BY: RR	PROJECT NO. 88649
	SHEET P-1 of

